



RE: Manufacturer's Certification,
Purple AWWA C900-16 Reclaimed Water

To Whom It May Concern:

In response to your request for Manufacturer's Certificate of Compliance for reclaimed water pipe, please be informed that Diamond 4" thru 60" CI dimension PVC purple water pipe is manufactured and tested to meet the dimension and performance requirements of AWWA C900-16. The pipe is marked "Reclaimed Water Not For Drinking" and every piece of pipe is hydrostatically tested to twice the rated pressure for 5 seconds according to the requirements of AWWA C900-16. All applicable testing is conducted in accordance with ASTM D1598, ASTM D1599, ASTM D2152, and ASTM D2412. Integral bell elastomeric sealed couplings meet the requirements of ASTM D3139, and the gaskets meet the requirements of ASTM F477.

If we may be of further assistance in this matter, please do not hesitate to call us. For your convenience, please use our toll-free phone 1-800-PVC-PIPE (1-800-782-7473.)

Sincerely,

DIAMOND PLASTICS CORPORATION